

検査項目	[事業主体名] 26 - 503 京都府 京都府				[事業主体名] 26 - 503 京都府 京都府				[事業主体名] 26 - 503 京都府 京都府																													
	[浄水場名] 01 - 00 宇治浄水場				[浄水場名] 02 - 00 木津浄水場				[浄水場名] 03 - 00 乙訓浄水場																													
[水源名] 天ヶ瀬ダム													[水源名] 木津川													[水源名] 桂川												
[原水の種類] ダム直接													[原水の種類] 表流水(自流)													[原水の種類] 表流水(自流)												
[1日平均浄水量] 51,415 (m ³) 原水													[1日平均浄水量] 31,473 (m ³) 原水													[1日平均浄水量] 26,611 (m ³) 原水												
	最高	最低	平均	回数	最高	最低	平均	回数	最高	最低	平均	回数																										
一般細菌	760	77	180	12	21000	110	3100	12	6800	120	1600	12																										
大腸菌(定量)(MPN/100ml)	23.0	1.0	7.0	12	1900.0	6.0	280.0	12	720.0	9.0	89.0	12																										
大腸菌(定性)																																						
カドミウム及びその化合物	<0.00030	<0.00030	<0.00030	4	<0.00030	<0.00030	<0.00030	4	<0.00030	<0.00030	<0.00030	4																										
水銀及びその化合物	<0.00005	<0.00005	<0.00005	4	<0.00005	<0.00005	<0.00005	4	<0.00005	<0.00005	<0.00005	4																										
セレン及びその化合物	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
鉛及びその化合物	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	0.001	<0.001	<0.001	4																										
ヒ素及びその化合物	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	0.001	<0.001	<0.001	4																										
六価クロム化合物	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4																										
亜硝酸態窒素	0.004	<0.004	<0.004	4	0.015	<0.004	0.009	4	0.012	0.004	0.009	4																										
シアン化物イオン及び塩化シアン	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
硝酸態窒素及び亜硝酸態窒素	0.40	0.30	0.35	4	1.10	0.70	0.90	4	0.50	0.40	0.45	4																										
フッ素及びその化合物	0.11	0.09	0.10	4	0.08	<0.08	<0.08	4	<0.08	<0.08	<0.08	4																										
ホウ素及びその化合物	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4	<0.1	<0.1	<0.1	4																										
四塩化炭素	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4	<0.0002	<0.0002	<0.0002	4																										
1,4-ジオキサン	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4																										
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	<0.004	<0.004	<0.004	4	<0.004	<0.004	<0.004	4	<0.004	<0.004	<0.004	4																										
ジクロロメタン	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	4																										
テトラクロロエチレン	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
トリクロロエチレン	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
ベンゼン	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
塩素酸	<0.06	<0.06	<0.06	4	<0.06	<0.06	<0.06	4	<0.06	<0.06	<0.06	4																										
クロロ酢酸	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	4	<0.002	<0.002	<0.002	4																										
クロロホルム	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12																										
ジクロロ酢酸	<0.003	<0.003	<0.003	4	<0.003	<0.003	<0.003	4	<0.003	<0.003	<0.003	4																										
ジブromクロロメタン	<0.01	<0.01	<0.01	12	<0.01	<0.01	<0.01	12	<0.01	<0.01	<0.01	12																										
臭素酸	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4	<0.001	<0.001	<0.001	4																										
総トリハロメタン	<0.004	<0.004	<0.004	12	<0.004	<0.004	<0.004	12	<0.004	<0.004	<0.004	12																										
トリクロロ酢酸	<0.003	<0.003	<0.003	4	<0.003	<0.003	<0.003	4	<0.003	<0.003	<0.003	4																										
プロモジクロロメタン	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12																										
プロモホルム	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12	<0.001	<0.001	<0.001	12																										
ホルムアルデヒド	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4	<0.008	<0.008	<0.008	4																										
亜鉛及びその化合物	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4																										
アルミニウム及びその化合物	0.14	0.03	0.06	12	0.77	<0.02	0.15	12	0.28	<0.02	0.08	12																										
鉄及びその化合物	0.20	0.08	0.13	4	1.50	0.22	0.61	4	0.49	0.07	0.21	4																										
銅及びその化合物	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4	<0.10	<0.10	<0.10	4																										
ナトリウム及びその化合物	11.0	7.3	9.0	4	10.0	5.9	8.0	4	8.3	4.4	6.7	4																										
マンガン及びその化合物	0.035	0.015	0.024	8	0.110	0.012	0.046	4	0.029	0.005	0.016	4																										
塩化物イオン	13.0	8.1	11.0	12	11.0	5.0	8.1	12	10.0	5.1	6.8	12																										
カルシウム、マグネシウム等(硬度)	41	30	36	4	37	26	31	4	34	24	31	4																										
蒸発残留物	85	73	78	4	159	80	111	4	88	73	79	4																										
陰イオン界面活性剤	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	4	<0.02	<0.02	<0.02	4																										
ジェオスミン	0.000002	<0.000001	0.000001	9	0.000003	<0.000001	0.000002	9	0.000004	<0.000001	0.000001	9																										
2-メチルイソボルネオール	0.000003	<0.000001	<0.000001	9	0.000001	<0.000001	<0.000001	9	<0.000001	<0.000001	<0.000001	9																										
非イオン界面活性剤	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4	<0.005	<0.005	<0.005	4																										
フェノール類	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4	<0.0005	<0.0005	<0.0005	4																										
有機物(TOCの量)	1.8	1.2	1.4	12	2.6	1.0	1.6	12	1.9	0.5	0.8	12																										
pH値	7.4	6.8	7.3	12	7.4	7.0	7.3	12	7.6	7.3	7.4	12																										
味																																						
臭気			2	12			2	12			2	12																										
色度	10.0	3.6	6.1	12	43.0	4.4	12.0	12	27.0	3.1	8.0	12																										
濁度	7.5	2.1	4.4	12	57.0	1.1	10.2	12	20.0	1.5	5.7	12																										